



Mailing Address:

Attn: BRIAN AND SARAH BANKS TRUST
1880 CENTURY PARK EAST #1600
LOS ANGELES, CA, 90067

Inspection Address:

Business Name: Arata Music
Recording
1660 9TH ST
SANTA MONICA, CA, 90404

Business/Mercantile Inspection Result

Inspection Status

Completed with failures

Inspected by

Andrew De Anda

Completed at

08/26/2026 07:20:08

Invoice Number(s)			
SMA- INV-2026-0003493			

Re-Inspection scheduled to be conducted on or after 09/23/2026 at 08:00

The Santa Monica Fire Department adopts the California Fire Code (CFC) with amendments under the City of Santa Monica Municipal Code 08.40.010. Under CFC 107.1, the Fire Department is authorized to enter and examine any building or structure or premises in accordance with CFC Section 104.3 for the purpose of enforcing this code.

Required Dates:

✖ Fail

ITEM: Automatic Fire Sprinkler 5-Year Test Cert - DOCUMENT CERTIFICATION DATE IN REMARKS

REMARK:

Expired?? No access.

Attempts made to no avail.

CODE: CFC - 901.6.1 - Standards - Fire protection systems shall be inspected, tested and maintained in accordance with the referenced standards listed in Table 901.6.1 and California Code of Regulations , Title 19, Division 1, Chapters 3 and 5. [California Code of Regulations, Title 19, Division 1, §904.1(a)] Inspection Requirements. [California Code of Regulations, Title 19, Division 1, §904.2(g)] Testing and Maintenance Requirements.

✖ Fail

ITEM: Fire Alarm Annual Test Cert - DOCUMENT CERTIFICATION DATE IN REMARKS

REMARK:

Expired?? No access.

Attempts made to no avail.

CODE: CFC - 901.6 - Inspection, testing and maintenance - Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, mechanical smoke exhaust systems and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed. All fire alarm systems, fire detection systems, automatic sprinkler or extinguishing systems, communication systems, and all other equipment, material or systems required by these regulations shall be maintained in an operable condition at all times in accordance with this code and California Code of Regulations , Title 19, Division 1.

✘ Fail

ITEM: Service & tag each extinguisher annually, and after any use. DOCUMENT EXPIRATION IN REMARKS

REMARK:

Expired?? No access.

Attempts made to no avail.

Access and Fire Lane:

✘ Fail

ITEM: Keys in the Knox box are maintain current/updated

REMARK:

Keys/Code needed to building??

No access. Attempts made to no avail.

CODE: CFC - 506.2 - Key box maintenance - The operator of the building shall immediately notify the fire code official and provide the new key where a lock is changed or rekeyed. The key to such lock shall be secured in the key box.

Per CFC 110.3.2 a notice of violation issued or served as provided by the Fire Code shall be complied with by the owner, the owner;s authorized agent, operator, occupant or other person responsible for the condition or violation to which the notice of violation pertains. Unless otherwise noted, all violations must come into compliance with-in **30 days** of issuance of this notice.

Inspection Signatures

Occupancy Contact Signature

Unable to sign:

NA

BRIAN AND SARAH BANKS TRUST
Billing Contact
310-556-6614
1880 CENTURY PARK EAST #1600, LOS
ANGELES, CA, 90067

Inspector Signature

Confirmed

Andrew De Anda
Fire Code Enforcement Officer
--
424-581-5195
Andrew.deanda@santamonica.gov